

METHOD #2 SINGLE VALVE

NOTE: FOR TM-26 BI-METAL VALVES ONLY



NOTE: THIS PIPING METHOD IS USED FOR SYSTEMS WITH A CIRCULATED FLOW OF EIGHT (8) GPM OR LESS.

SEE INSTALLATION INSTRUCTIONS FOR VALVE SPECIFIC PIPING DIAGRAMS AND SET UP PROCEDURE.

FOR MULTIPLE TEMPERED LOOPS A BALANCING VALVE AND CHECK VALVE MUST BE INSTALLED ON EACH LOOP AFTER TEMPERED FIXTURES.

